

TEST REPORT

Report No.: **2507260038**

Page 1 of 2
Date: 02-08-2025

Issued To:

M/s MQB MERCANTILES PRIVATE LIMITED

10/2, Lottogollahalli, Outer Ring Road, R.M.V. Extension II Stage,
Bengaluru, Bengaluru Urban, Karnataka, 560094

Sample Description : UPVC PROFILE
Sample Received Date : 26-07-2025
Sample Drawn By : Client
Specification : --
Test Requested : THERMAL CONDUCTIVITY
Test Method : Refer to Attached Pages.
Test Result : Refer to Attached Pages.

SAMPLE PICTURE



Authentication: To Check authenticity of Test report (s), Scan QR code to get original data.



Terms & Conditions:

BIS, DGQA & Various Govt. Approved Laboratory
ISO 9001 : 2015, ISO 14001:2015 & OHSAS 18001:2007 Certified Laboratory

1. Sample will not be retained more than one month for chemical and three month for mechanical unless specified instructed. 2. Samples analysis conducted on as received basis and followed by customer description, unless specified otherwise. 3. The laboratory will not be liable for sample destroy/damage during testing, unless instructed otherwise. 4. Any Complaints matter about this report should be communicated in written, within 7 days of issue of this report. 5. The result listed refer only to the tested samples and applicable parameters as described by customer. Endorsement of product is neither inferred nor implies. 6. Total liability of our laboratory is limited to the invoiced amount only. 7. This report cannot be used as and evidence in a court of law without the written approval of the laboratory.

MSF 5.10.01





TEST REPORT

Report No.: 2507260038

Page 2 of 2
Date: 02-08-2025

I. Mechanical

1.

THERMAL CONDUCTIVITY TEST

Test performed on: 01-08-2025 to 02-08-2025

Test Method: ASTM C518

Test Parameter	Unit	Result
Thermal Conductivity	W/m.K	0.22

-----End of Report-----



Rahul

ASSISTANT MANAGER- TESTING

Authorized Signatory

Authentication: To Check authenticity of Test report (s), Scan QR code to get original data.



BIS, DGQA & Various Govt. Approved Laboratory

ISO 9001 : 2015, ISO 14001:2015 & OHSAS 18001:2007 Certified Laboratory

Terms & Conditions:

1. Sample will not be retained more than one month for chemical and three month for mechanical unless specified instructed. 2. Samples analysis conducted on as received basis and followed by customer description, unless specified otherwise. 3. The laboratory will not be liable for sample destroy/damage during testing, unless instructed otherwise. 4. Any Complaints matter about this report should be communicated in written, within 7 days of issue of this report. 5. The result listed refer only to the tested samples and applicable parameters as described by customer. Endorsement of product is neither inferred nor implies. 6. Total liability of our laboratory is limited to the invoiced amount only. 7. This report cannot be used as and evidence in a court of law without the written approval of the laboratory.

MSF5.10.01

